




MONTHLY REPORT FROM EMISSION MONITORING IN TITAN CEMENTARNICA USJE- KILN No.4



September 2009	Dust (mg/Nm ³)	MДК 50mg/m ³	SO ₂ (mg/Nm ³)	MДК 400mg/m ³	NOx (mg/Nm ³)	MДК 1300mg/m ³	Comments
	MДК 50mg/m ³		MДК 400mg/m ³		MДК 1300mg/m ³		
1	2	50	195	400	992	1300	
2	1	50	229	400	755	1300	
3	2	50	228	400	992	1300	
4	2	50	211	400	890	1300	
5	1	50	223	400	807	1300	
6	1	50	235	400	949	1300	
7	1	50	247	400	842	1300	
8	1	50	217	400	977	1300	
9	1	50	234	400	994	1300	
10	2	50	288	400	1045	1300	
11	1	50	272	400	963	1300	
12	1	50	254	400	833	1300	
13	1	50	247	400	552	1300	
14	1	50	246	400	688	1300	
15	1	50	235	400	629	1300	
16	2	50	247	400	621	1300	
17	2	50	252	400	598	1300	
18	1	50	245	400	663	1300	
19	1	50	252	400	659	1300	
20	2	50	239	400	704	1300	
21	2	50	226	400	894	1300	
22	1	50	236	400	889	1300	
23	1	50	261	400	777	1300	
24	1	50	225	400	808	1300	
25	1	50	234	400	752	1300	
26	2	50	271	400	758	1300	
27	2	50	287	400	1004	1300	
28	1	50	263	400	880	1300	
29	1	50	242	400	668	1300	
30	2	50	319	400	900	1300	
31		50		400		1300	
Average	1	50	245	400	816	1300	

MLV: Maximum Limit Value

Eplanations: The monthly average values are calculated on the half hour emissin values. Measured values of the concentrations are calculated at 10 vol. of O₂
 Results of the measurments are represented in Nm3 (Nm3 - T=273K, P=101,3kP, dry gas)c