




## MONTHLY REPORT FROM EMISSION MONITORING IN TITAN CEMENTARNICA USJE - KILN No.3



October 2013	Dust (mg/Nm <sup>3</sup> )	МДК 50mg/m <sup>3</sup>	SO <sub>2</sub> (mg/Nm <sup>3</sup> )	МДК 400mg/m <sup>3</sup>	NO <sub>x</sub> (mg/Nm <sup>3</sup> )	МДК 1300mg/m <sup>3</sup>	Comments
	МДК 50mg/m <sup>3</sup>		МДК 400mg/m <sup>3</sup>		МДК 1300mg/m <sup>3</sup>		
01.10.2013	13,12	50	19,3	400	966,36	1300	
02.10.2013	14,64	50	25,06	400	1100,83	1300	
03.10.2013	15	50	17,78	400	1153,94	1300	
04.10.2013	16,29	50	14,16	400	1119,06	1300	
05.10.2013	16,12	50	15,11	400	1038,01	1300	
06.10.2013	15,54	50	14,19	400	1111,5	1300	
07.10.2013	14,71	50	19,72	400	1022,08	1300	
08.10.2013	14,13	50	17,51	400	1012,97	1300	
09.10.2013	14,27	50	17,7	400	1037,26	1300	
10.10.2013	13,29	50	20,54	400	1059,05	1300	
11.10.2013	/	50	/	400	/	1300	
12.10.2013	/	50	/	400	/	1300	
13.10.2013	/	50	/	400	/	1300	
14.10.2013	/	50	/	400	/	1300	
15.10.2013	/	50	/	400	/	1300	
16.10.2013	15,69	50	22,11	400	1187,8	1300	
17.10.2013	19,75	50	19,92	400	1203,75	1300	
18.10.2013	15,56	50	22,56	400	1142,79	1300	
19.10.2013	15,45	50	17,67	400	1177,61	1300	
20.10.2013	16,51	50	16,84	400	1153,05	1300	
21.10.2013	16,34	50	16,09	400	1142,62	1300	
22.10.2013	16,99	50	18,79	400	1121,61	1300	
23.10.2013	16,29	50	24,41	400	1184,32	1300	
24.10.2013	16,87	50	16,66	400	1128,57	1300	
25.10.2013	16,39	50	18,62	400	1061,69	1300	
26.10.2013	16,38	50	14,05	400	1180,04	1300	
27.10.2013	16,28	50	12,64	400	1135,51	1300	
28.10.2013	17,25	50	21,06	400	1102,9	1300	
29.10.2013	21,18	50	17,72	400	1093	1300	
30.10.2013	13,44	50	18,62	400	1037,04	1300	
31.10.2013	12,46	50	13,06	400	1034,22	1300	
<b>Average</b>	<b>15,8</b>	<b>50</b>	<b>18,1</b>	<b>400</b>	<b>1104,1</b>	<b>1300</b>	

**MLV: Maximum Limit Value**

Забелешка: Поради сервисни активности печка бр.3 не работеше од 11.10.2013 до 15.10.2013 год.

