




MONTHLY REPORT FROM EMISSION MONITORING IN TITAN CEMENTARNICA USJE - KILN No.4



August 2014	Dust (mg/Nm ³) МДК 30mg/m ³	МДК 30mg/m ³	SO ₂ (mg/Nm ³) МДК 400mg/m ³	МДК 400mg/m ³	NOx (mg/Nm ³) МДК 800mg/m ³	МДК 800mg/m ³	Comments
	9,96	30	36,19	400	682,76	800	
	9,83	30	16,14	400	675,47	800	
	10,72	30	23,39	400	662,82	800	
	11,99	30	44,1	400	730,03	800	
	13,3	30	20,83	400	670,96	800	
	14,55	30	22,92	400	661	800	
	15,32	30	18,8	400	675,2	800	
	16,73	30	50,03	400	623,51	800	
	18,22	30	86,59	400	651,67	800	
	19,76	30	152,92	400	672,94	800	
	18,17	30	128,97	400	682,87	800	
	14,94	30	10,76	400	682,43	800	
	13,6	30	15,54	400	654,4	800	
	12,4	30	16,59	400	686,94	800	
	10,33	30	16,88	400	683,94	800	
	8,15	30	12,95	400	712,15	800	
	7,49	30	12,35	400	683,34	800	
	7,94	30	14,25	400	697,59	800	
	8,28	30	43,55	400	705,93	800	
	7,12	30	17,24	400	706,63	800	
	6,5	30	11,82	400	620,1	800	
	6,28	30	15,36	400	638,38	800	
	6,62	30	16,53	400	725,02	800	
	6,42	30	14,9	400	698,45	800	
	6,53	30	14,46	400	696,21	800	
	6,44	30	15,79	400	726,84	800	
	6,99	30	20,1	400	704,35	800	
	6,78	30	15,84	400	724,42	800	
	6,61	30	22,84	400	682,08	800	
	6,6	30	13,11	400	697,61	800	
	6,43	30	14,17	400	692,69	800	
Average	10,1	30	29,5	400	686,2	800	

MLV: Maximum Limit Value

Eplanations: The monthly average values are calculated on the half hour emissin values. Measured values of the concentrations are calculated at 10 vol. of O₂
 Results of the measurments are represented in Nm3 (Nm3 - T=273K, P=101,3kP, dry gas)c