




## MONTHLY REPORT FROM EMISSION MONITORING IN TITAN CEMENTARNICA USJE - KILN No.3






June 2011	Dust (mg/Nm <sup>3</sup> ) МДК 50mg/m <sup>3</sup>	МДК 50mg/m <sup>3</sup>	SO <sub>2</sub> (mg/Nm <sup>3</sup> ) МДК 400mg/m <sup>3</sup>	МДК 400mg/m <sup>3</sup>	NOx (mg/Nm <sup>3</sup> ) МДК 1300mg/m <sup>3</sup>	МДК 1300mg/m <sup>3</sup>	Comments
1	6	50	51	400	535	1300	
2	6	50	77	400	478	1300	
3	6	50	102	400	628	1300	
4	5	50	113	400	446	1300	
5	6	50	123	400	488	1300	
6	6	50	156	400	502	1300	
7	6	50	131	400	569	1300	
8	6	50	134	400	555	1300	
9	6	50	146	400	539	1300	
10	6	50	145	400	495	1300	
11	6	50	129	400	386	1300	
12	6	50	124	400	331	1300	
13	6	50	155	400	327	1300	
14	6	50	194	400	380	1300	
15	6	50	141	400	371	1300	
16	6	50	112	400	414	1300	
17	6	50	84	400	538	1300	
18	6	50	130	400	529	1300	
19	6	50	120	400	507	1300	
20	6	50	115	400	480	1300	
21	6	50	160	400	488	1300	
22	6	50	206	400	496	1300	
23	6	50	198	400	690	1300	
24	6	50	179	400	544	1300	
25	6	50	207	400	523	1300	
26	6	50	214	400	585	1300	
27	6	50	181	400	551	1300	
28	6	50	141	400	466	1300	
29	6	50	140	400	448	1300	
30	6	50	60	400	477	1300	
31		50		400		1300	
<b>Average</b>	<b>6</b>	<b>50</b>	<b>139</b>	<b>400</b>	<b>492</b>	<b>1300</b>	

**MLV: Maximum Limit Value**

Eplanations: The monthly average values are calculated on the half hour emissin values. Measured values of the concentrations are calculated at 10 vol. of O<sub>2</sub>  
 Results of the measurments are represented in Nm3 (Nm3 - T=273K, P=101,3kP, dry gas)c

## MONTHLY REPORT FROM EMISSION MONITORING IN TITAN CEMENTARNICA USJE - KILN No.4



June 2011	Dust (mg/Nm <sup>3</sup> ) МДК 50mg/m <sup>3</sup>	МДК 50mg/m <sup>3</sup>	SO <sub>2</sub> (mg/Nm <sup>3</sup> ) МДК 400mg/m <sup>3</sup>	МДК 400mg/m <sup>3</sup>	NOx (mg/Nm <sup>3</sup> ) МДК 1300mg/m <sup>3</sup>	МДК 1300mg/m <sup>3</sup>	Comments
1	4	50	129	400	654	1300	
2	3	50	129	400	561	1300	
3	3	50	113	400	479	1300	
4	3	50	115	400	515	1300	
5	3	50	115	400	539	1300	
6	3	50	125	400	732	1300	
7	3	50	161	400	668	1300	
8	4	50	151	400	645	1300	
9	4	50	198	400	565	1300	
10	4	50	185	400	459	1300	
11	4	50	150	400	456	1300	
12	4	50	136	400	430	1300	
13	4	50	107	400	466	1300	
14	4	50	133	400	573	1300	
15	4	50	115	400	559	1300	
16	4	50	137	400	435	1300	
17	4	50	119	400	452	1300	
18	4	50	129	400	618	1300	
19	4	50	113	400	640	1300	
20	4	50	143	400	659	1300	
21	4	50	127	400	729	1300	
22	4	50	140	400	758	1300	
23	4	50	169	400	904	1300	
24	4	50	177	400	516	1300	
25	4	50	157	400	755	1300	
26	4	50	157	400	639	1300	
27	4	50	123	400	556	1300	
28	4	50	184	400	673	1300	
29	4	50	116	400	806	1300	
30	4	50	107	400	650	1300	
31		50		400		1300	
<b>Average</b>	<b>4</b>	<b>50</b>	<b>139</b>	<b>400</b>	<b>603</b>	<b>1300</b>	

**MLV: Maximum Limit Value**

Eplanations: The monthly average values are calculated on the half hour emissin values. Measured values of the concentrations are calculated at 10 vol. of O<sub>2</sub>  
 Results of the measurmets are represented in Nm3 (Nm3 - T=273K, P=101,3kP, dry gas)c